

RESOLUTION NO. 02-25

A RESOLUTION OF THE RIDGECREST CITY COUNCIL ACCEPTING A PROPOSAL FOR INSPECTION AND REPAIR OF WATER SYSTEM CORROSION IN THE KERR-McGEE CENTER AND AMENDING THE ANNUAL BUDGET

The Ridgecrest City Council resolves as follows:

Section 1. In the course of maintenance and inspection activities during the Fall of 2000 personnel from Security Engineering noted corrosion problems with the water service facilities at the Kerr-McGee Center. Observed problems were corrected at that time. This included replacement of corroded bolts, replacement of pipe fittings, etc..

Section 2. In the Fall of 2001 a field survey was conducted by Farwest Corrosion Control Company to determine the cause of the problem. The results of this survey determined that the cause of the problem is due the chemical nature of the soil. When consistently wet the soil becomes very corrosive and thus the source of the problem. This occurs in areas subject to landscape irrigation. The extent of the problem cannot be fully determined without excavating at the various locations. To date approximately eight (8) locations have been determined as being potential problem areas.

Section 3 The Director of Public Works requests authorization to award the contract to Security Engineering in the amount not to exceed ten thousand dollars(\$10,000) to inspect and repair corrosion problems with the water system in the Kerr-McGee Center as directed by the Director of Public Works.

The City Council of the City of Ridgecrest hereby authorizes the Director of Public Works to award the contract for the inspection and repair of the water system in the Kerr-McGee Center.

Section 4 The budget is hereby amended to reflect the increased cost.


APPROVED AND ADOPTED this 6th day of March 2002, by the following vote:

AYES: Mayor Morgan, Council Members Carter, Holloway, Martin, and Rollins


NOES: None

ABSENT: None

ABSTAIN: None


Steven P. Morgan, Mayor

ATTEST:


Harvey M. Rose
City Clerk